



Food, Food Products, Beverages, Fertilizer, Chemicals Testing Laboratory.

- Govt. of India, Ministry of Agricultural marketing & Inspection Dept approved "AGMARK" Food testing Lab.
- Govt. of Maharashtra approved Soil & Water testing Laboratory (Nashik Region)
- ◆ ISO 9001 : 2008 Certified Companest Report

	No. of the last of		
1.	Test Reports No: Date of Issue	Rep. SATRL/23-24/09/205 12-09-2023	
3.	Name & Address of the Customer	Kashinath Palod Public School Jalgaon Dist - Jalgaon	
4.	Sample Name Sample Collected and submitted By	Drinking water RO	
6. 7.	Date of Sample Receipt : Date of Reporting	10/9/2023 12/9/2023 SATRL/23-24/09/205	

Chemical Test: -

**TEST RESULT** 

Sr. No.	Test Parameters	Results	Requirement As per IS 10500 Specification	Test Method
1	pH Value	6.90	6.50-8.50	IS 3025(P-11)1983
2	Electrical Conductivity	62.2 microsimon	C= 00	IS 3025(P-14)1984
3	Total Dissolved Solids	40	500 mg/lit	IS 3025(P-16)1984
4	Chlorides, as Cl	15.6	250 mg/lit	IS 3025(P-32)1983
5	Calcium, as Ca	6.10	75 mg/lit	IS 3025(P-40)1984
6	Magnesium, as Mg	0.10	30 mg/lit	IS 3025(P-46)1984
7	Total Hardness, as	16	200 mg/lit	IS 3025(P-21)1984
8	Total Alkalinity, as	20	200 mg/lit	IS 3025(P-17)1984
9	Iron, as Fe	0.005	0.30 mg/lit	IS 3025(P-53)1984
10	Nitrate, as NO3	1.10	45 mg/lit	IS 3025(P-34)1984
11	Sulphate, as SO4	0.6	200 mg/lit	IS 3025(P-24)1983
12	Fluoride, as F	0.02	1.0 mg/lit	IS 3025(P-60)1984
	iological Testing			
13	Total coliform bacteria	Absent	Absent in 100 ml	IS 15185:2016
15	E.coli	Absent	Absent in 100 ml	IS 15185:2016

\*Remark-Water is potable in respect of above said tested parameters Jadhar

There Tested by

(Chemist)

esting & R TEST

Verified by (Microbiologist) (Chandrakant Jadhav) Revieved & Authorized by (Technical Manager) ( A.G Mahajan )

aloda